

Subsurface Sewage Treatment System Minimum Setback Distances

Feature	Sewage tank or Holding tank	Soil treatment or Absorption area	Building sewer, or Supply lines
Water supply well less than 50 feet deep	50'	100'	50'*
Any other water supply well or buried water suction line	50'	50'	50'*
Building	10'	20'	
Property line	10'	10'	

The Ordinary High Water Level of:

Natural Environment Lake	150'	150'
Recreational Development Lake	100'	100'
General Development Lake	100'	100'
Remote and Forested Rivers	150'	150'
Tributary Stream	100'	100'

*Setback may be reduced to 20' if Schedule 40 pipe is used and is pressure tested.